


2/8

"STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance"



DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT NANGLOI, DELHI-110041

आज़ादी का
अमृत महोत्सव

Water Samples collected "Sant Hari Dass Sr. Sec. Public School" Opp. Airforce Station Bani Camp, Najafgarh
New Delhi- 110043 Vide Challan No. 231 Dated :- 18.08.2023 & Sant Hari Dass College of Higher
S1:- DJB Supply S2 :- R. O. water Education

S. No.	Particulars	Units	Limit		S1	S2
			Acceptable	Permissible		
PHYSICAL EXAMINATION						
1.	Date of collection	-----	--	--	29.08.2023	29.08.2023
2.	Date of Analysis	-----	--	--	30.08.2023	30.08.2023
3.	Colour	Hazen	5.0	15	Clear	Clear
4.	Odour	-----	No. Objectionable		No Obj.	No Obj.
5.	Turbidity	N.T.U.	1.0	5.0	1.10	1.04
6.	PH value	-----	6.5	8.5	7.38	7.32
7.	Electrical Conductivity	µmho	--	--	328.5	324.2
8.	Total dissolved solids	mg/l	500	2000	213.52	210.73
CHEMICAL EXAMINATION						
9.	Phenolphthalein Alkalinity	mg/l	--	--	Nil	Nil
10.	Total Alkalinity	mg/l	200	600	88	86
11.	Total Hardness	mg/l	200	600	132	128
12.	Calcium Hardness	mg/l	--	--	88	84
13.	Magnesium Hardness	mg/l	--	--	44	44
14.	Calcium as Ca	mg/l	75	200	35.2	33.6
15.	Magnesium as Mg	mg/l	30	100	10.56	10.56
16.	Ammonia as N	mg/l	0.5	N.R.	NIL	NIL
17.	Nitrite as N	mg/l	---	--	NIL	NIL
18.	Nitrate as NO ₃	mg/l	45	N.R.	2.6	2.2
19.	Sulphate	mg/l	200	400	38	32
20.	Chloride	mg/l	250	1000	38	36
21.	Dissolved Iron	mg/l	0.3	N.R.	0.04	0.02
22.	Fluoride	mg/l	1	1.5	0.08	0.06
23.	Cyanide	mg/l	0.05	N.R.	ND	ND
24.	Residual Chlorine	mg/l	0.20	1.0	1.20	1.0
BACTERIOLOGICAL EXAMINATION						
25.	Coli-form per 100 ml at 37°C	MPN	0		0	0

REMARKS : As per tested parameters Sample - S1 & S2 can be used for drinking purpose.

Chemist

[Signature]
Principal


Sant Hari Dass Public School
Bani Camp, Najafgarh,
New Delhi-110043

[Signature]
21/9/23
ACWA

[Signature]
Chairman
Sant Hari Dass Education Society (Regd.)
Vill. Baprola, Najafgarh, New Delhi-43



MUNICIPAL CORPORATION OF DELHI
PUBLIC HEALTH DEPARTMENT, WEST ZONE
DR. SAHIB SINGH VERMA NIGAM BHAWAN
SHIVAJI ENCLAVE, RAJA GARDEN, NEW DELHI - 110027



No.DHO/WZ/2024/D- 223

Dated: 05/07/24

HEALTH CERTIFICATE

1. Name of the School Sant Hari Dass Sr. Sec. Public School
2. School address Opp. Air Force Station, Bani Camp, Najafgarh, New Delhi - 110043
3. No of shifts 01 Timings:- 08:00 AM to 2:00 PM
4. No of students:- Boys 667 Girls 460 Total 1127
5. No of staff:- Male 14 Female 43 Total 57

Accommodation provide for classroom as under:-

- Floor area in the classroom is sufficient /insufficient Sufficient
- Classes are well lighted/ ill lighted Well lighted
- Classrooms are well ventilated/ill ventilated Well ventilated
- Classes are kept/ not kept neat and clean Neat & clean
- Building/ classrooms require/ do not require white wash etc. not required
- Drinking water is wholesome/ not wholesome wholesome
- Latrine arrangement is sanitary/ insanitary Sanitary from health point of view

Note:- Valid for one year from the date of issue


Principal
Sant Hari Dass Public School
Bani Camp, Najafgarh,
New Delhi-110043


Dy. Health Officer
West Zone
Dy Health Officer
West Zone
MCD
Chairman
Sant Hari Dass Education Society (Regd.)
Vill. Baprola, Najafgarh, New Delhi-43